

Minimum Requirements for Luxury Lift Traction Elevators - Florida

- 1. 52" x 57" clear inside hoistway dimensions when using an accordion style solid gate.
- 2. 2017 FBC CODE 8" Minimum pit built to withstand a 5,100 lb. impact load.
- 3. 102" clear hoistway overhead for Std. cab. 114" clear hoistway overhead for 8'-0" cab.
- 4. 12" minimum return on rail side wall. If this cannot be obtained, contact office for approval.
- 5. If masonry construction, rail wall needs to be poured solid.
- Rail side blocking for wood frame hoistways must be two 2 x 12's sandwiched together, running vertically the entire length of the hoistway 12" on center of either side of the rail wall centerline. (Please see rail wall structural drawing.)
- 7. Legal machinery space with access door. (Please see access door drawing.)

20 Residential Dr., Crawfordville, FL 32327 Toll Free (800) 832–2004 Fax (850) 926–5319 www.ResidentialElevators.com