

CAGE LIGHT FIXTURE AND LIGHT SWITCH (BY G.C.)

4 x 4 ELECTRICAL BOX FOR 240 VAC, DEDICATED 30 AMP (G.C. / OWNER PROVIDED)

4 x 4 ELECTRICAL BOX FOR 120 VAC, DEDICATED 30 AMP (G.C. / OWNER PROVIDED)

GFI 110 VAC RECEPTACLE (BY G.C.)

OVERHEAD CLEARANCE  
102" MIN. FOR STD. CAB HEIGHT  
114" MIN. FOR 8'-0" CAB HEIGHT  
(IF LESS THAN 102" IS AVAILABLE, CONSULT R.E.I.)

HINGED MACHINERY ACCESS DOOR  
18 H" x 24 W" MIN.  
24 H" x 24 W" MAX.  
(BY G.C.)

ALTERNATE LATCHABLE ACCESS DOOR  
HINGED AT TOP  
18 H" x 24 W" MIN.  
24 H" x 24 W" MAX.  
(BY G.C.)

LINE ELEVATOR SHAFT WALLS WITH PLYWOOD (PREFERRED) OR DRYWALL  
CHECK LOCAL CODE REQUIREMENTS FOR THICKNESS

LANDING DOORS  
2'-8" OR 3'-0" W  
BY 6'-8" OR 8'-0" H  
SOLID CORE REQUIRED  
(BY G.C.)

TOTAL TRAVEL

PIT DEPTH  
2017 FBC CODE 8" MIN.

ELEVATOR PIT  
MINIMUM 4" THICK REINFORCED CONCRETE SLAB  
TO WITHSTAND 5,100 Lbs.

### TYPICAL ELEVATION

TYPICAL 2 STOP HOISTWAY LAYOUT

#### NOTES:

RESIDENTIAL ELEVATORS (REI) CONTROL SYSTEM CONTAINS THE 240 VAC AND 120 VAC DISCONNECTS, HOWEVER; GC/ OWNER MUST PROVIDE DEDICATED CIRCUIT AND WIRE TO 4" x 4" BOX (1 FOR 240 VAC & 1 FOR 120 VAC) IN MACHINE SPACE PER DRAWING. SEE REI ELECTRICAL REQUIREMENTS BROCHURE FOR FURTHER DETAILS.

1. RAIL IS CONCRETE ANCHORED WITH 1/2" REDHEAD OR CONCRETE SLEEVE BOLTS GR.5 - 1/2" x 4" ANCHORS
2. RAIL BRACKETS ARE LAGGED WITH 1/2" x 4" HEX HEAD LAG SCREWS
3. FOR EACH 1" HOISTWAY IS REDUCED IN WIDTH OR DEPTH CAR SIZE IS REDUCED BY 1" IN WIDTH OR DEPTH

THE INFORMATION CONTAINED HEREIN IS SOLELY OWNED BY RESIDENTIAL ELEVATORS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT WRITTEN PERMISSION FROM RESIDENTIAL ELEVATORS, INC. IS STRICTLY PROHIBITED.



Elevating your standard of living

AUGUST 2016

## LUXURY LIFT TRACTION LLT

JOB NAME:

TRACTION HOISTWAY (FLORIDA)  
ELEVATION (TYP.)

DRAWING NUMBER

HOR 01 FLA