



RESIDENTIAL ELEVATORS (REI) CONTROL SYSTEM CONTAINS THE 240 VAC AND 120 VAC DISCONNECTS, HOWEVER; GC/ OWNER MUST PROVIDE DEDICATED CIRCUIT AND WIRE TO 4" x 4" BOX (1 FOR 240 VAC & 1 FOR 120 VAC) IN MACHINE SPACE PER DRAWING. SEE REI ELECTRICAL REQUIREMENTS BROCHURE FOR FURTHER DETAILS.

TYPICAL ELEVATION AND LAYOUT

(ADJACENT MACHINE ROOM)

THE INFORMATION CONTAINED HEREIN IS SOLELY OWNED BY RESIDENTIAL ELEVATORS, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT WRITTEN PERMISSION FROM RESIDENTIAL ELEVATORS, INC. IS STRICTLY PROHIBITED.



DRAWN:	CHECKED:	DATE:	REVISION
G.P.		03/30/04	REVISED
G.P.		10/09/09	CHANGE 6'-8" TO STD.
G.P.	E.S.	03/11/11	REMOVE DISCONNECTS, ADD 4 X 4 BOXES
JOB NAME:			DRAWING NUMBER
HYDRAULIC HOISTWAY AND MACHINE ROOM ELEVATION (TYP.)			HYD 01